


SHEET NOTES:

- ① COLD WATER PIPE BOND SHALL BE MADE AT A POINT NO FURTHER THAN 5 FEET FROM ENTRANCE OF BUILDING.
- ② CONCRETE ENCASED ELECTRODE PER NEC ART. 250-81C AT UFER GROUND.
- ③ GROUNDING ELECTRODE AT THE TRANSFORMER SHALL BE GROUNDED TO THE NEAREST BUILDING STRUCTURE STEEL.

ELECTRICAL ONE LINE DIAGRAM
NOT TO SCALE

DO NOT SCALE DRAWINGS
ALL DIMENSIONS IN INCHES
UNLESS NOTED OTHERWISE

DATE:	
REVISION DESCRIPTION:	
REV:	
	
ANDY'S BEST CAD 1323 CARLYLE PARK CIRCLE HIGHLANDS RANCH, CO 80129 303-808-3352 WWW.ANDYSBESTCAD.COM	
DRAWN:	A. LANDT
DESIGNED:	
CLIENT:	02/15/16
DATE:	NONE
SCALE:	
DRAWING TITLE:	ELECTRICAL ONE-LINE DIAGRAM
DRAWING NO.:	E1
	01 OF 01