


CHILLED WATER SYSTEM SCHEMATIC

SCALE: NOT TO SCALE

- ALL AHU CW VALVES ARE 2-WAY PNEUMATIC W/PILOT POSITIONERS
- AHU 1-4 CHW EWT = 45°F DESIGN
- ALL OTHER AHU'S CHW EWT = 44°F DESIGN
- 5 TOTAL BOOSTER PUMPS = 2058 GPM DESIGN



DRAWING NO:
M01
OF

DRAWING TITLE:
CHILLED WATER SYSTEM SCHEMATIC

PROJECT:
HOSPITAL
CHILLER REPLACEMENT
MECHANICAL
CONSTRUCTION DRAWINGS

DRAWN: ABC
DESIGNED:
CLIENT:
DATE: 03/10/22
SCALE: NONE

ANDY'S BEST CAD
1323 CARLYLE PARK CIRCLE
HIGHLANDS RANCH, CO 80129
303-808-3352
WWW.ANDYSBESTCAD.COM

ENGINEER'S STAMP

REVISION DESCRIPTION:

DATE:

© 2022 ANDY'S BEST CAD. ALL RIGHTS RESERVED. THIS DRAWING IS THE PROPERTY OF ANDY'S BEST CAD AND IS PROTECTED BY COPYRIGHT LAWS OF THE UNITED STATES OF AMERICA. ANY UNAUTHORIZED USE OF THE INFORMATION CONTAINED HEREIN OR PART THEREOF IS STRICTLY PROHIBITED. RECEIPT OR POSSESSION THEREOF DOES NOT CONVEY OR TRANSFER ANY RIGHT TO MAKE, COPY, MANUFACTURE AND/OR SELL EITHER THE DRAWING OR THE ITEMS SHOWN THEREON.