

**COOLING TOWER PIPING SCHEMATIC**  
 M-3 SCALE: NOT TO SCALE

**OWNER-FURNISHED COOLING TOWER SCHEDULE**

DESIGNATION	TYPE	FLOW	CONDENSER WATER			MAX ENT AIR WB	ELECTRICAL DATA			NO OF CELLS	LOCATION	MODEL	REMARKS
			GPM TOTAL	WATER ENT	WATER LVG		NO REQ'D	HP/EA	VOLTS/#/Hz				
CT-1,CT-2	INDUCED DRAFT	CROSSFLOW	1200	90	80	67	1	20	460/3/60	1 PER TOWER	ROOF	MARLEY NC 8304F1	ALTERNATE #1

NOTES:


DATE:	
REVISION DESCRIPTION:	
ENGINEER'S STAMP	

ANDY'S BEST CAD  
 1323 CARLYLE PARK CIRCLE  
 HIGHLANDS RANCH, CO 80129  
 303-808-3352  
 WWW.ANDYSBESTCAD.COM

DRAWN: ABC  
 DESIGNED:  
 CLIENT: 03/11/22  
 DATE: NONE  
 SCALE:

PROJECT:  
 HEALTH CARE OFFICE BUILDING  
 COOLING TOWER REPLACEMENT  
 MECHANICAL  
 CONSTRUCTION DRAWINGS

DRAWING TITLE:  
 COOLING TOWER PIPING SCHEMATIC



DRAWING NO:  
 M03  
 of